

Your Ref: 241015
Our Ref: HT/TPD/SD/PL/ 59538
File no: 59538 4B
Date: 05/06/2024



CC: Cllr Lewis Barber - County Member
Rob Lee – Development Management
dm.busman@essexhighways.org

Director for Highways and Transportation

To: Colchester Borough Council
PO Box 889
Rowan House
33 Sheepen Road
COLCHESTER
CO3 3WG

County Hall
Chelmsford
Essex CM1 1QH

Recommendation

Application No. 241015

Applicant Mr & Mrs Krayesteyn-Watts

Site Location Highfields, Church Lane, Little Tey Colchester CO6 1HX

Proposal Erection of 1 No. two storey dwelling and associated car parking

From a highway and transportation perspective the impact of the proposal is acceptable to the Highway Authority subject to the following requirements:

1. Prior to first occupation, parking in accordance with the Essex Parking Standards – The Parking Standards: Design and Good Practice (September 2009), shall be provided.

Reason: To ensure that on street parking of vehicles in the adjoining streets does not occur in the interests of highway safety and that appropriate parking is provided in accordance with Policy DM8 of the Development Management Policies as adopted as County Council Supplementary Guidance in February.

2. Prior to occupation of the development, the access at its centre line shall be provided with a clear to ground visibility splay with dimensions of 2.4 metres by 43 metres as measured from and along the nearside edge of the carriageway. Such vehicular visibility splays shall be provided before the access is first used by vehicular traffic and retained free of any obstruction at all times.

Reason: To provide adequate inter-visibility between vehicles using the access and those in the existing public highway in the interest of highway safety in accordance with policy DM1 of the Development Management Policies as adopted as County Council Supplementary Guidance in February 2011.

3. Prior to occupation of the development the vehicular access shall be constructed at right angles to the highway boundary and to the existing carriageway. The width of the access at its junction with the highway shall not be less than 5.5 metres and shall be retained at that width for 6 metres within the site and shall be provided with an appropriate dropped kerb vehicular crossing of the footway/highway verge.

Reason: to ensure that vehicles can enter and leave the highway in a controlled manner in the interest of highway safety in accordance with policy DM1 of the Development Management Policies as adopted as County Council Supplementary Guidance in February 2011.

4. Cycle parking shall be provided in accordance with the EPOA Parking Standards. The approved facility shall be secure, convenient, covered and provided prior to occupation and retained at all times.

Reason: To ensure appropriate cycle parking is provided in the interest of highway safety and amenity in accordance with Policy DM8 of the Development Management Policies as adopted as County Council Supplementary Guidance in February 2011.

5. No unbound material shall be used in the surface treatment of the vehicular access within 6 metres of the highway boundary.

Reason: To avoid displacement of loose material onto the highway in the interests of highway safety in accordance with policy DM1 of the Development Management Policies as adopted as County Council Supplementary Guidance in February 2011.

Informative

- The above requirements should be imposed by way of negative planning conditions or planning obligation agreements as appropriate.
- All work within or affecting the highway should be laid out and constructed by prior arrangement with and to the requirements and satisfaction of the Highway Authority, details to be agreed before commencement of the works. An application for the necessary works should be made to development.management@essexhighways.org
- Under Section 148 of the Highways Act 1980 it is an offence to deposit mud, detritus etc. on the highway. In addition, under Section 161 any person, depositing anything on a highway which results in a user of the highway being injured or endangered is guilty of an offence. Therefore, the applicant must ensure that no mud or detritus is taken onto the highway, such measures include provision of wheel cleaning facilities and sweeping/cleaning of the highway.
- There shall be no discharge of surface water onto the Highway.
- Prior to commencement of the development, the areas within the curtilage of the site for the purpose of loading / unloading / reception and storage of building materials and maneuvering of all vehicles, including construction traffic shall be provided clear of the highway.
- Under Section 23 of the Land Drainage Act 1991, prior written consent from the Environment Agency is required to build any culvert (pipe) or structure (such as a dam or weir) to control or alter the flow of water within an ordinary watercourse. Ordinary watercourses include ditches, drains and any other networks of water which are not classed as Main River.

